



416 N. PRODUCTION ST.
ABERDEEN, SD 57401
PHONE: (605) 225-1212

August 5, 2026

Re: Sanitary Sewer Lift Station Improvements
Prairiewood Sanitary District
Aberdeen, South Dakota
Helms Project #: A-10441
CWSRF #: C461290-01

ADDENDUM NUMBER 1

The following modifications are made to the plans and specifications for the Sanitary Sewer Lift Station Improvements project.

PLANS

Sheet 7; Lift Station Details

The dimensions of the lift station wet well and valve pit **shall be changed to 7'-0" x 7'-0" for both structures**. This change was made to provide additional room for the installation of the lift station components.

The size designation (1") for the Air Release Valve shall be removed. The contractor shall furnish the smallest sized air release valve necessary to achieve proper functioning of the lift station.

CONTRACT DOCUMENTS AND SPECIFICATIONS

SECTION 00 52 00 – AGREEMENT BETWEEN OWNER AND CONTRACTOR FOR CONSTRUCTION CONTRACT (STIPULATED PRICE)

ARTICLE 4 – CONTRACT TIMES, Paragraph 4.02A.

Due to anticipated lead times for various components of the lift station control panel the following changes were made to the completion dates for the project. Paragraph 4.02A shall be replaced with the following:

The work shall be substantially complete on or before **February 19th, 2027**, and completed and ready for final payment in accordance with Paragraph 15.06 of the General Conditions on or before **March 5th, 2027**.

SECTION 33 32 13.13 – DUPLEX SUBMERSIBLE PUMP LIFT STATIONS

Paragraphs 1.04B and 1.04C shall be removed from the specifications.

Paragraph 2.04A shall be replaced with the following:


The contractor shall furnish and install one (1) NEMA/UL 3R stainless steel weather proof enclosure for **240 volts, single phase, 60 hertz power supply**. The control panel shall include the following:

ALL OTHER ITEMS OF THE PLANS AND SPECIFICATIONS REMAIN UNCHANGED.

BY 

DATE 8/5/2026

PROJECT ENGINEER - HELMS AND ASSOCIATES



=====

FIRM NAME: _____ BY: _____

TITLE: _____ DATE: _____

ATTACH THIS SIGNED ADDENDUM TO THE BID FORM WHEN SUBMITTING AND/OR
ACKNOWLEDGE THE ADDENDUM ON THE BID FORM.