

May 12, 2026

**RE: Muth Electric Corporate Office Addition North Parking Improvements
Mitchell, South Dakota
SPN #16278**

BID LETTING: Friday, May 15, 2026 @ 2:00 PM

ADDENDUM NUMBER 1

The following modifications are to be made to the plans and specifications for the Ohlman Utility and Street Improvements Project.

Plans

Sheet 7 – Delete the paragraph titled “STRIPING” in its entirety and replace with the following:

STRIPING

1. Paint used for pavement marking shall be a water-based paint suitable and intended for use in pavement marking. The paint shall be installed per the manufacturer’s recommendation.

Sheet 7 – Add the following paragraph:

TRAFFIC CONTROL

1. Traffic control shall include 2 each type 2 barricades located at the driveway entrance and 15 each 42” delineator posts located along the south extents of the project. The Contractor shall be responsible for furnishing, placing, and moving the traffic control devices as necessary to provide a safe work space.

All other items of the plans and specifications remain unchanged.

Jacob D. Sonne

Jacob Sonne, Project Engineer
Schmucker, Paul, Nohr & Associates

The undersigned hereby acknowledges receipt of Addendum Number 1 to the plans and specifications for the *Muth Electric Corporate Office Addition North Parking Improvements Project*.

FIRM NAME _____
BY _____
TITLE _____
DATE _____

ATTACH THIS SIGNED ADDENDUM NO. 1 TO THE BID FORM WHEN SUBMITTING.